



BV LCIE
CHINA
Number

N° 1866AS07ZEM28910

ATTESTATION of conformity with European Directives

Product: **Grid-tied Microinverter**
Reference **QS1, QS1200**
Issued to **ALTENERGY POWER SYSTEM INC.**

Address **No.1 Yatai Road, Jiaxing 314050 Zhejiang Province,P.R. China**

Manufacturer **ALTENERGY POWER SYSTEM INC.**

Technical characteristics **See Next Page**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 62109-1: 2010	ZEM-18AP0385FCSHP-1	12/07/2018
EN 62109-2: 2011	ZEM-18AP0385FCSHP-2	12/07/2018

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), July, 12th, 2018.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



LCIE

BV LCIE
CHINA
Number

N° 1866AS07ZEM28910

Model / Type	QS1	QS1200
MPP DC voltage range [V]	22-48	
MAX Input DC voltage [V]	60	
Max Input DC current [A]	4*12	
Output AC voltage [V]	230V, 50Hz	
Max.Output AC current [A]	5,22	
Output power [W]	1200	

Shanghai (P.R. China),), July, 12th, 2018.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com

Version 3/2016.02.19




BV LCIE
CHINA
Number

N°1866AB07ZEM29052

ATTESTATION of conformity with European Directives



Product : Grid-tied Microinverter
Reference : QS1200, QS1
Issued to : ALTENERGY POWER SYSTEM INC.
Address : No.1 Yatai Road, Jiaxing, 314050, Zhejiang Province, P. R. China
Manufacturer : ALTENERGY POWER SYSTEM INC.
Technical characteristics : Refer to report for detail

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

Electromagnetic Compatibility Directive 2014/30/EU

Standards	Report number	Report date
EN 61000-6-3:2007+A1:2011 EN 61000-6-4:2007+A1:2011 EN 61000-6-2:2005 EN 61000-6-1:2007 EN 61000-3-2:2014 EN 61000-3-3:2013	ZEM-18AP0385FTSHPB	23/07/2018

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), Jul. 23, 2018.

Zhaoqian YU
Expert



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.